

-
+ 2
- 3
+ 4
5 +
6 -
7 +
8 -
9 +
0 -

➔ Dimension

Width × Height × Depth: 2.8 mm × 0 mm × 7 mm

➔ Applications

This apparatus is used for transmitting signals between field devices and process control system. It can

installation in the control room or high density field cabinet, DIN 35 mm installation is convenient for installation and displacement.

- ❍ The devices were designed for use in pollution degree 2 and overvoltage category III as per IEC/EN 60664- . If used in areas with higher pollution degree, the devices need to be protected accordingly.
- ❍ Installation position shall not be affected by strong mechanical vibration; impact and electromagnetic induction from signal terminal and power supply, should conformity with the requirements on electromagnetic interference resistance of products in Class 3 industrial field atmosphere stipulated in IEC 6 000-4; the atmosphere shall be free from gases that are corrosive to metal and plastic components.
- ❍ The apparatus must be installed, connected and adjusted by qualified personnel in non-hazardous area according with the instruction manual.
- ❍ The operator must strictly comply with the relevant local safety standards and guidelines.

➔ Supplementary instructions

- ❍ Our company reserves the right to change the product information without prior notification to the user. If the contents of the description are different from website or sample, this description shall prevail.